





Massachusetts Water Resources Authority






Quabbin Precipitation






System Yield - Quabbin and Wachusett





System Withdrawl






Water Use


Total Water Use: MWRA Core Communities

Arlington, Belmont, BWSC, Brookline, Chelsea, Everett, Framingham, Lexington, Malden, Medford, Melrose, Milton, Newton, Norwood, Quincy, Reading, Revere, Somerville, Stoneham, Waltham, Watertown, Winthrop






Quabbin Reservoir Level





Miles Surveyed for Leaks



During the 1st Quarter of FY18, 37.73 miles of water mains were inspected. Surveyed below target due to staff training and availability. Metering staff provided leak detection assistance to eight communities this quarter



***Supply and Delivery of Ferrous Chloride
to the Deer Island Treatment Plant
WRA-4425***

November 15, 2017



Supply and Delivery of Ferrous Chloride to Deer Island

- Used at Deer Island to:
 - Pretreat sludge to minimize hydrogen sulfide (H_2S) formation in digester gas
 - Prevent struvite in digesters and downstream pipes





What Is Struvite And Why Do We Have To Prevent It?

Struvite = Magnesium Ammonium Phosphate Hexahydrate $Mg (NH_4) PO_4 (H_2O)_6$



- A scale that forms in anaerobic digesters with secondary treatment processes
- Mostly limited to coastal plants (salt water is high in mg)
- Clogs lines increasing equipment downtime. Could take entire digester unit out for months or years



How Do We Have To Prevent Or Remediate?

1. Prevention:


- Add iron salts like Ferrous Chloride (FeCl_2) to bind up PO_4

2. Remediate:

- Mechanical cleaning
- High pressure wash

Last resort:

- Replace Pipe





Are There Alternatives? Innovative Technologies


- Residuals technology options assessment/recent staff investigation

- OSTARA process

- Forced struvite precipitation in controlled part of process

- CALPrex Process

- Similar to OSTARA, different end product – dicalcium phosphate





Recommendation/Conclusions

- Innovative technologies
 - Not fully proven, some may be pilot scale only
 - Require major process changes at Deer Island (costly)
 - Still require some iron salt addition to pretreat for H₂S in digester gas
- Pipe replacement too disruptive to operation, impacting ability to treat
- Chemical prevention and light remediation best combination



***Clinton Wastewater Treatment Plant
Phosphorus Reduction Design, CA/RE
Contract 7377, Amendment 4***

November 15, 2017



Clinton Wastewater Treatment Plant





Total Phosphorus Limits

Average Daily Flow: 3.0 MGD

Maximum Daily Flow: 8.0 MGD

Peak Hourly Flow: 12.0 MGD

Existing Total Phosphorus Limits:

- 1.0 mg/l from May 1 to October 31
- No required limit from November 1 to April 30

Future Total Phosphorus Limits (April 2019):

- 0.15 mg/l from April 1 to October 31
- 1.0 mg/l from November 1 to March 31




Phosphorus Reduction Facility





Process Schematic






Mixers, Coagulation and Flocculent Tanks






Disk Filter and Phosphorus Operations Touch Screen





Disc Filter Process



Disc Filter Process




Disc Filters





Disc Filter Backwash Units





Amendment 4 Summary

- Six-month time extension due to contractor delays
- Increases Contract amount by \$249,645.48
- Includes additional level of effort for:
 - six months of resident engineering services
 - additional on-site meetings/inspections/observations
 - construction advice/interpretation/clarification
 - review and processing of contractor submittals
 - additional start-up services



***Southern Extra High Pipeline,
Section 111 – Boston
Contract 6454, Change Order 3***

November 15, 2017



This Contract





36-inch Ductile Iron Pipe Being Installed Dedham Parkway, Boston





Existing Usiflex Pipe Joint On Section 42





Tee Installed On Section 42





12-inch Drain Repair on Enneking Parkway





Typical Installation of Vertical Offsets






36-inch Gate Valve Vault





Blasting Preparation and Documentation





Ledge Removal on Enneking Parkway





Removing Rock






Pipe Installation Progress Plan

- LEGEND:**
EXISTING MWRA WATER MAIN
NEW WATER MAIN INSTALLED
PROPOSED WATER MAIN TO BE INSTALLED

CURRENT THROUGH OCTOBER 30, 2017
% PIPE INSTALLED: 95.2% (10,467/11,000)
PRODUCTION RATE: 59.1 FT/DAY (BASED ON 177 WORKING DAYS)
% TIME ELAPSED: 59.9% (467/780)





***Wachusett Aqueduct Pump Station
Contract 7157, Change Order 25***

November 15, 2017



Construction Update - Front Entrance





Construction Update - Pump Station





Construction Update – Wachusett Aqueduct Connection





Construction Update – Wachusett Aqueduct Connection





Change Order 25 – Pipe Gallery Dehumidification

- Change to Desiccant System from Refrigerant Type System
- Refrigerant type dehumidification was recently installed in the Carroll UV Building
- UV dehumidifiers experienced operational problems during warm weather
- Led to re-evaluation of Pump Station dehumidification options
- Timing too late to modify bid documents



Change Order 25 – Pump Power Fluctuation Ride Through

- Millisecond power fluctuations - pumps susceptible to shutdown
- Pump start-up – over 1 hour
- May experience several power fluctuations per day
- For power ride through:
 - Provide DC Battery Circuits in each MCC
 - Provide UPS for each Pump Control Valve





Change Order 25 – Summary

Item	Cost
Pipe Gallery Dehumidification	\$184,456
Power Fluctuation Ride Through	\$106,507
Total	\$290,963



Wachusett Aqueduct Pumping Station

