

Lead Service Line Sample Results: 2018 Q1 (January-March)

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
3887892	Melrose	1	3/27/18	14.3	ppb
3894818	Melrose	1A	3/27/18	6.40	ppb
3895285	Melrose	2	3/27/18	5.21	ppb
3895286	Melrose	2A	3/27/18	36.9*	ppb
3887893	Melrose	3	3/27/18	16.0*	ppb
3894817	Melrose	3A	3/27/18	14.7	ppb
3895289	Melrose	4	3/28/18	1.04	ppb
3895290	Melrose	4A	3/28/18	3.37	ppb
3895275	Melrose	5	3/28/18	4.92	ppb
3895276	Melrose	5A	3/28/18	15.5*	ppb
3895287	Melrose	6	3/28/18	29.6*	ppb
3895288	Melrose	6A	3/28/18	2.90	ppb
3895280	Melrose	7	3/28/18	27.4*	ppb
3895279	Melrose	7A	3/28/18	7.21	ppb
3895281	Melrose	8	3/28/18	114*	ppb
3895282	Melrose	8A	3/28/18	63.9*	ppb
3895277	Melrose	9	3/29/18	17.6*	ppb
3895278	Melrose	9A	3/29/18	14.7	ppb
3895283	Melrose	10	3/29/18	4.50	ppb
3895284	Melrose	10A	3/29/18	1.40	ppb

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of **15 ppb**.