

MPDH Sample Results: 2018 Q3 (July - September)

<u>Case/Sample ID</u>	<u>Project Name</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
429262	DPH-PB	1	7/6/18	1.16	ppb
429262	DPH-PB	1A	7/6/18	< 1.00	ppb
429411	DPH-PB	2	7/19/18	6.11	ppb
429411	DPH-PB	2A	7/19/18	< 1.00	ppb
429679	DPH-PB	3	7/24/18	< 1.00	ppb
429679	DPH-PB	3A	7/24/18	< 1.00	ppb
429927	DPH-PB	4	7/30/18	< 1.00	ppb
429927	DPH-PB	4A	7/30/18	< 1.00	ppb
430013	DPH-PB	5	7/31/18	< 1.00	ppb
430013	DPH-PB	5A	7/31/18	< 1.00	ppb
430115	DPH-PB	6	7/31/18	162*	ppb
430115	DPH-PB	6A	7/31/18	205*	ppb
430236	DPH-PB	7	8/10/18	< 1.00	ppb
430236	DPH-PB	7A	8/10/18	< 1.00	ppb
430176	DPH-PB	8	8/27/18	7.54	ppb
430176	DPH-PB	8A	8/27/18	< 1.00	ppb
430119	DPH-PB	9	8/28/18	< 1.00	ppb
430119	DPH-PB	9A	8/28/18	1.27	ppb
429294	DPH-PB	10	9/6/18	< 1.00	ppb
429294	DPH-PB	10A	9/6/18	< 1.00	ppb
430261	DPH-PB	11	9/10/18	1.16	ppb
430261	DPH-PB	11A	9/10/18	1.09	ppb
430878	DPH-PB	12	9/10/18	< 1.00	ppb
430878	DPH-PB	12A	9/10/18	< 1.00	ppb
431042	DPH-PB	13	9/20/18	< 1.00	ppb
431042	DPH-PB	13A	9/20/18	< 1.00	ppb
430876	DPH-PB	14	9/21/18	< 1.00	ppb
430876	DPH-PB	14A	9/21/18	< 1.00	ppb
430907	DPH-PB	15	9/25/18	< 1.00	ppb
430907	DPH-PB	15A	9/25/18	< 1.00	ppb
428329	DPH-PB	16	9/27/18	< 1.00	ppb
428329	DPH-PB	16A	9/27/18	< 1.00	ppb
201407 (430115 repeat)	DPH-PB	17	10/7/18	5.06	
201407 (430115 repeat)	DPH-PB	17A	10/7/18	3.37	

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”