

## Lead Service Line Sample Results: 2019 Q1 (January-March)

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
4054494	Medford	1	2/6/19	1.16	ppb
4054495	Medford	1A	2/6/19	1.46	ppb
4054978	Medford	2	2/20/19	1.65	ppb
4054979	Medford	2A	2/20/19	2.21	ppb
4073480	Medford	3	3/25/19	39.8	ppb
4073481	Medford	3A	3/25/19	47.8	ppb

- **ppb** = parts per billion or  $\mu\text{g/L}$
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of **15 ppb**.