

Lead Request Sample Results: 2020 Q2 (April - June)

Data below show approved lead results from tests of drinking water in residential homes following a request from the local water department. No specific information is available on whether the home had a lead service lines or other risk for lead in the drinking water.

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
4267320	Winthrop	1	4/22/20	6.62	ppb
4267652	Marlborough	2	4/24/20	< 1.00	ppb
4275657	Medford	3	4/30/20	< 1.00	ppb
4275656	Medford	4	4/30/20	< 1.00	ppb
4273666	Winthrop	5	5/1/20	7.16	ppb
4273665	Winthrop	6	5/6/20	5.98	ppb
4275655	Medford	7	5/7/20	< 1.00	ppb
4275723	Winthrop	8	5/12/20	2.08	ppb
4280170	Medford	9	5/13/20	< 1.00	ppb
4281722	Medford	10	5/20/20	0.0977	ppb
4286070	Medford	11	5/25/20	< 1.00	ppb
4285182	Malden	12	5/28/20	20.3*	ppb
4285182	Malden	12A	5/28/20	20.1*	ppb
4289306	Milton	13	6/11/20	4.30	ppb
4289307	Milton	14	6/11/20	< 1.00	ppb
4298147	Medford	15	6/20/20	< 1.00	ppb
4298146	Medford	16	6/20/20	< 1.00	ppb
4298148	Medford	17	6/21/20	< 1.00	ppb
4303436	Medford	18	6/29/20	< 1.00	ppb

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of **15 ppb**.