

Lead Service Line Sample Results: 2020 Q2 (April - June)

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
4296713	Milton	1	6/23/20	1.78	ppb
4297614	Milton	2	6/23/20	0.808	ppb
4296711	Milton	3	6/25/20	0.793	ppb
4296712	Milton	4	6/25/20	0.334	ppb

- **ppb = parts per billion or $\mu\text{g/L}$**
- **“<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”**
- **Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of 15 ppb.**