



MWRA: Current Information about PFAS Testing (April 2021) Test Results

| PFAS Analyte | Metro Boston Result | CVA Result |
|--|---------------------|--------------|
| PFAS6 (regulated) | | |
| PFHxS | Not detected | Not detected |
| PFHpA | Trace* | Not detected |
| PFOA | Trace* | Trace* |
| PFOS | Trace* | Not detected |
| PFNA | Not detected | Not detected |
| PFDA | Not detected | Not detected |
| Sum of PFAS6 - compare to MassDEP MCL of 20 ng/l | 0 ng/l | 0 ng/l |
| Unregulated PFAS | | |
| PFBS | Trace* | Not detected |
| PFHxA | Trace* | Not detected |
| NEtFOSAA | Not detected | Not detected |
| NMeFOSAA | Not detected | Not detected |
| PFDoA | Not detected | Not detected |
| PFTeDA | Not detected | Not detected |
| PFTTrDA | Not detected | Not detected |
| PFUnA | Not detected | Not detected |
| 11Cl-PF3OUdS | Not detected | Not detected |
| 9Cl-PF3ONS | Not detected | Not detected |
| Adona | Not detected | Not detected |
| HFPO-DA | Not detected | Not detected |

* trace amounts are present, but they are below the minimum concentration that can be reported as a quantified value.

MCL = Maximum Contaminant Level, highest level allowed